




MGM Industries

*SIMULATION PERFORMANCE &
SOLAR HEAT GAIN REPORT*

*Series "7010"
Transom*

NCTL-110-10908-01



NATIONAL CERTIFIED TESTING LABORATORIES

FIVE LEIGH DRIVE • YORK, PENNSYLVANIA 17406 • TELEPHONE (717) 846-1200
FAX (717) 767-4100
www.nctlinc.com

Simulation Performance, Solar Heat Gain Coefficient, Visible Transmittance and Condensation Resistance Calculation Report

REPORT NO: NCTL-110-10908-01
SIMULATION DATE: 09/19/07
REPORT DATE: 09/19/07

Client: MGM Industries
287 Freehill Road
Hendersonville, TN 37075

Product Line: MGM Industries' Series "7010" Transom

Specification: NFRC 100-2004: "Procedure for Determining Fenestration Product U-Factors".
NFRC 200-2004: "Procedure for Determining Fenestration Product Solar Heat
Gain Coefficients and Visible Transmittance at Normal Incidence".
NFRC 500-2004: "Procedure for Determining Fenestration Product
Condensation Resistance Values".
Therm 5.x / Window 5.x NFRC Simulation Manual (Approved at test date)

**Procedures
and
Compliance:** All U-factor, Solar Heat Gain Coefficients, Visible Transmittance and
Condensation Resistance values were calculated using the following
characteristics: a default value of 0.30 solar absorptance for all products
other than window glazed wall and sloped glazing which have a solar
absorptance of 0.50. The best glazing option was used as the configuration
for SHGC and VT specialty products table. NCTL is a NFRC accredited
simulation laboratory and this simulation was conducted in full compliance
with NFRC requirements. This report does not constitute an opinion or
endorsement by the laboratory. Ratings values included in this report are for
submittal to an NFRC-licensed IA and are not meant to be used directly for
labeling purposes. Only those values identified on a valid Certification
Authorization Report (CAR) by an NFRC accredited Inspection Agency (IA) are
to be used for labeling purposes. Rounding per IEEE/ASTM SI 10-1997
except section 5.4.1.3.

PRODUCT LINE DESCRIPTION

General: The product line modeled is MGM Industries' Series "7010" Transom.

Model Size Simulations: 2000mm x 600mm (78.740" x 23.622")

Note: All product drawings are included in Attachment A.

Weatherseals: None

Reinforcement: None

Finish: Vinyl

Dividers: Where applicable, dividers were not modeled because the gap between dividers and lites were greater than 3mm. For Solar Heat Gain and Visual Light Transmittance default dividers less than 1” and greater or equal to 1” and default patterns were used for simulations.

Group Leaders: The following group leaders are actual simulated individual products per NFRC 4.2.4 and the NFRC Technical Interpretations where applicable. All remaining individual products' U-factors in the corresponding groups are represented by the group leader's U-factor.

COG Group Leader: Individual products which differ from another (base) individual product in glazing tint and/or obscenity (including obscure glass, fritted glass, and wired glass) only may be assumed to have the same U-factor as the base product unless this change is associated with a change in coating properties.

COG Group Leader:

Glazing ID	Glazing Description	U _{COG}
001	2mm AFG Clear / .553” Air / 2mm AFG Clear	0.481 *
002	2mm AFG TiAC#36 / .553” Air / 2mm AFG Clear	0.298 *

* Group Leader

Modeling Assumptions and Comments Deemed Important:

Sealing Rules:

All cavities that are opened to the exterior within a frame section shall be modeled according to ISO 15099, Section 6.7.1, which states that cavities greater than 2mm but equal to or less than 10 mm shall be modeled as “slightly ventilated air cavities”. For physical testing purposes the product is sealed at the inside surface with tape or equivalent to prevent air infiltration. Air cavities created by this sealing technique must be simulated with the standard NFRC “Frame Cavity” material. If cavities on the frame are sealed (covered) to the surround panel with tape or equivalent, those cavities are also filled with NFRC “Frame Cavity” material within the simulation model. If the frame is not covered or sealed, those areas are left hollow or opened within the simulation model.

Continuous elements:

All elements continuous within the product line are identified from the Bill-of-Materials and detailed drawings via the referenced dimensions and cut lengths as compared to the overall size of the product.

General Notes:

The Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation, and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.

Miscellaneous assumptions:

1. The screen extrusions were not modeled.
2. All radii are simulated at angles.
3. Any spacer simulated using a spacer system from the Frame Spacer Library match the required configurations for this manufacturer's spacer system.
4. The modeling was performed in accordance with the manufacturer's assembly drawing from a DXF file.

Component Area and Frame Heights:

Frame heights, calculated areas, area weighted values for U-factor, SHGC, and VT, and center –of-glazing are located in approved NFRC simulation programs for all individual products.

Specialty Products Table: The specialty products method allows the manufacturer to determine the overall product SHGC and VT for any glazing option. The center of glass SHGC and/or VT must be determined using WINDOW 5.2. The method gives overall product SHGC and VT indexed on center of glass properties.

SHGC	No Dividers	Dividers <1"	Dividers ≥1"
0.00	0.002	0.004	0.007
1.00	0.774	0.702	0.633

VT	No Dividers	Dividers <1"	Dividers ≥1"
0.00	0.000	0.000	0.000
1.00	0.772	0.697	0.626

$$SHGC = SHGC_0 + SHGC_{COG} (SHGC_1 - SHGC_0)$$

$$VT = VT_0 + VT_{COG} (VT_1 - VT_0)$$

NCTL Therm Section Filename Methodology

Filename Codes Example: CU_HD2_003.THM	
CU	Spacer (Intercept)
HD	Frame Section (Head)
2	Glass Size (2.5mm)
003	Glazing ID #3

Individual Product Descriptions and Model Size Matrix of U-Factors, SHGC, VT & CR

All U-factors are given in BTU/HR/ft²/°F

Product Description	Product Number	Pane ID (Exterior)	Pane ID (Interior)	Pane Thickness (Exterior)	Pane Thickness (Interior)	Gap	Gap Fill	% of Gap Fill	Emissivity Surface 2	Emissivity Surface 3	U-factor C-O-G	SHGC C-O-G	VT C-O-G	Spacer	Grid Type	Tint	U-factor	Condensation Resistance	Solar Heat Gain Coefficient (ND)	Visual Transmittance (ND)	Solar Heat Gain Coefficient (<1")	Visual Transmittance (<1")
CLR_SS_AIR	001	885	885	0.098	0.098	0.553	AIR				0.50	0.80	0.83	CU-D	N,G	CL	0.47	45	0.62	0.64	0.56	0.58
CLR_DS_AIR		887	887	0.118	0.118	0.514	AIR				0.50	0.79	0.82	CU-D	N,G	CL	0.47	45	0.61	0.63	0.55	0.57
TiAC36#2_SS_AIR	002	964	885	0.098	0.098	0.553	AIR		0.034		0.30	0.37	0.69	CU-D	N,G	LE	0.33	55	0.29	0.53	0.26	0.48
TiAC36#3_SS_AIR		885	964	0.118	0.118	0.514	AIR			0.034	0.30	0.47	0.69	CU-D	N,G	LE	0.33	55	0.36	0.53	0.33	0.48
TiAC36#2_DS_AIR		965	887	0.098	0.098	0.553	AIR		0.034		0.29	0.37	0.68	CU-D	N,G	LE	0.33	55	0.28	0.52	0.26	0.47
TiAC36#3_DS_AIR		887	965	0.118	0.118	0.514	AIR			0.034	0.29	0.46	0.68	CU-D	N,G	LE	0.33	55	0.36	0.52	0.33	0.47

A baseline product test in accordance with the "NFRC 102: Test Procedure for Measuring the Steady-State Thermal Transmittance of Fenestration Systems" is required in order to validate the "Model Size Matrix of U-Values" as previously indicated. Per Section 1.4.3 of NFRC 100-2004, "the baseline product is the individual product selected for validation testing". **The individual product selected as the baseline product shall be the lowest simulated individual product or an individual product having a simulated U-factor within 0.60 W/ (m²*K) (0.10 BTU/HR/ft²/°F) or 20% of the listed lowest simulated U-factor.**

Product Description	Pane ID (Exterior)	Pane ID (Interior)	Pane Thickness (Exterior)	Pane Thickness (Interior)	Gap	Gap Fill	Emissivity Surface 3	Spacer	Grid Type	U-factor
TiAC36#3_DS_AIR Overall Size: 47.25 x 59.25	887	965	0.118	0.118	0.514	AIR	0.034	CU-D	N,G	0.32

Note:

1. For lowest U-factor listings where multiple individual products are shown, validation testing can be conducted on any of the configurations listed.
2. Actual simulated individual products are required for product line validation testing.
3. All individual products in the product line were simulated using the approved NFRC THERM program.

For the purposes of validation testing, production line units and sizes shall be used to represent the baseline products. Representative sizes are therefore defined as the production sizes with the least deviation (D) from the model sizes, calculated per NFRC 100. The previously listed model sizes shall be used for baseline product validation testing.

Copies of this report and the detailed product drawings will be retained by NCTL for a period of four (4) years. This report may not be reproduced, except in full, without the approval of NCTL. The results only to the fenestration product simulated. The attached diskette(s) contain(s) all required NFRC data and software files.

NATIONAL CERTIFIED TESTING LABORATORIES

JUSTIN M. ROBINSON

NFRC Accredited Simulator

Simulator-In-Responsible-Charge

Attachments

Report Log

Product Line: MGM Industries' Series "7010" Transom

Date:
09/19/07 - Original Report issued to MGM Industries and Inspection Agency

NFRC CODES

Door	
Code	Description
EM	Embossed
FL	Flush
LF	Full Lite
LH	1/2 - Lite
LQ	1/4 - Lite
LT	3/4 - Lite
N	Not Applicable
RP	Raised Panel

Grid	
Code	Description
G	Grids between the glass
N	No Muntins
S	Simulated Divided Lites
T	True Muntins

Sealant	
Code	Description
D	Dual Seal Spacer System
N	Not Applicable
S	Single Seal Spacer System

Gap Fill	
Code	Description
AIR	Air
AR3	Argon/Krypton/Air Mixture
ARG	Argon
KRY	Krypton
N	Not Applicable

Glass Tint	
Code	Description
AZ	Azurlite
BG	Blinds between the Glazing
BL	Blue
BZ	Bronze
CL	Clear
DV	Dynamic Glazing (Variable)
DY	Dynamic Glazing (Non-Variable)
EV	Evergreen
GC	Gold (reflective coating)
GD	Gold
GR	Green
GY	Gray
LE	Low 'e' Coating
OT	Other (use comment field)
RC	Solar or Reflective Coating
RG	Roller shades between Glazing
RS	Silver (reflective coating)
SF	Suspended Polyester Film
SR	Silver

Spacer		
Code	Type	Definition
A1-D	Aluminum	Aluminum spacer system - dual sealed.
A1-S	Aluminum	Aluminum spacer system - single sealed.
A2-D	Aluminum (thermally-broken)	Thermally improved aluminum spacer system - dual sealed.
A2-S	Aluminum (thermally-broken)	Thermally improved aluminum spacer system - single sealed.
A3-D	Aluminum-reinforced polymer	Polymer spacer material with aluminum substance - dual sealed.
A3-S	Aluminum-reinforced polymer	Polymer spacer material with aluminum substance - single sealed.
A4-D	Aluminum/Wood	Composite spacer system of two materials - dual sealed.
A4-S	Aluminum/Wood	Composite spacer system of two materials - single sealed.
A5-D	Aluminum-reinforced butyl	Butyl spacer material with aluminum substrate - dual sealed.
A5-S	Aluminum-reinforced butyl	Butyl spacer material with aluminum substrate - single sealed.
A6-D	Aluminum/Foam/Aluminum	Two aluminum spacers separated by foam-type material - dual sealed
A6-S	Aluminum/Foam/Aluminum	Two aluminum spacers separated by foam-type material - single sealed
A7-D	Aluminum U-shaped	U-shaped spacer system embedded in sealant - dual sealed.
A7-S	Aluminum U-shaped	U-shaped spacer system embedded in sealant - single sealed.

Spacer		
Code	Type	Definition
A8-D	Aluminum-Butyl Composite	Exposed corrugated aluminum spacer with butyl - dual sealed.
A8-S	Aluminum-Butyl Composite	Exposed corrugated aluminum spacer with butyl - single sealed.
CS-D	Coated Steel	Coated Steel (galvanized or tinplated) - Dual seal
CS-S	Coated Steel	Coated Steel (galvanized or tinplated) - Single seal
CU-D	Coated Steel U-Shaped	Coated Steel (galvanized or tinplated) U-shaped spacer system embedded in sealant - Dual sealed
CU-S	Coated Steel U-Shaped	Coated Steel (galvanized or tinplated) U-shaped spacer system embedded in sealant - Single sealed
ER-D	EPDM Reinforced Butyl	EPDM reinforced butyl spacer system - dual sealed.
ER-S	EPDM Reinforced Butyl	EPDM reinforced butyl spacer system - single sealed.
FG-D	Fiberglass	Fiberglass - dual sealed.
FG-S	Fiberglass	Fiberglass - single sealed.
GL-S	Glass	Welded glass edge condition at glazing perimeter.
N	Not Applicable	
OF-D	Organic Foam	Organic-based foam spacer system - dual sealed.
OF-S	Organic Foam	Organic-based foam spacer system - single sealed.
P1-D	Polycarbonate- Butyl Composite	Exposed corrugated polycarbonate spacer with butyl - dual sealed.
P1-S	Polycarbonate- Butyl Composite	Exposed corrugated polycarbonate spacer with butyl - single sealed.
PU-D	Polyurethane foam	Polyurethane foam - dual sealed.
PU-S	Polyurethane foam	Polyurethane foam - single sealed.
S2-D	Steel (thermally-broken)	Stainless steel spacer with urethane thermal break - dual sealed.
S2-S	Steel (thermally-broken)	Stainless steel spacer with urethane thermal break - single sealed.
S3-D	Steel/Foam/Steel	Two steel spacers separated by foam-type material - dual sealed.
S3-S	Steel/Foam/Steel	Two steel spacers separated by foam-type material - single sealed.
S5-D	Steel reinforced butyl	Butyl spacer material with stainless steel substrate - dual sealed.
S5-S	Steel reinforced butyl	Butyl spacer material with stainless steel substrate - single sealed.
S6-D	Steel U-channel w/ thermal cap	U-shaped steel spacer system with a thermal cap - dual sealed.
S6-S	Steel U-channel w/ thermal cap	U-shaped steel spacer system with a thermal cap - single sealed.
SS-D	Stainless Steel	Stainless Steel - Dual Seal
SS-S	Stainless Steel	Stainless Steel - Single Sealed
SU-D	Stainless Steel U-Shaped	Stainless Steel U-shaped spacer system embedded in sealant - Dual sealed
SU-S	Stainless Steel U-Shaped	Stainless Steel U-shaped spacer system embedded in sealant - Single sealed
TP-D	Thermo-plastic	Thermo-plastic - dual sealed.
TP-S	Thermo-plastic	Thermo-plastic - single sealed.
TS-D	Thermo-plastic	Thermoplastic spacer with stainless steel substrate - dual-sealed
TS-S	Thermo-plastic	Thermoplastic spacer with stainless steel substrate - single-sealed
WD	Wood	Wood spacer system
ZF-D	Silicone Foam	Silicone foam spacer system - dual sealed.
ZF-S	Silicone Foam	Silicone foam spacer system - single sealed.
ZS-D	Silicone/Steel	Combination of two separate spacers: a steel spacer and silicone spacer - dual sealed.
ZS-S	Silicone/Steel	Combination of two separate spacers: a steel spacer and silicone spacer - single sealed.

ATTACHMENT A

Product Drawings

TEST SPECIMEN COMPLIES
WITH THESE DETAILS
ANY DEVIATION IS NOTED.

Bill of Materials Listing

Print Date: Aug 17, 2007

TEST COMPLETE: 9/19/07
NCTL-110-10908-01

Product: 7010


Type: TR

Assembly Code	Part #	Description	Qty	Height	Width	Unit Code	Vert Hor	Sub Assy	Add Color	Fixed Length	W/Nailing Fin
GLASS	1CL	Default Glass Type	1.00	3.1250	3.1250	SF		IA	N		
GLSSPC	SWG-11/16	Glass Spacer	2.00		3.9375	LI	W	IA	N		
GLSSPC	SWG-11/16	Glass Spacer	2.00	6.3750		LI	H	IA	N		
MUNCLP	10946-002	Muntin Clips	1.00			EA		IA	N		
MUNTNH	536006	Muntin Bar Horizontl	1.00		5.3125	LI	W	IA	Y		
MUNTNV	536006	Muntin Bar Vertical	1.00	5.4375		LI	H	IA	Y		

End of Subassembly IA *****											
GLVNLH	V-185	Glazing Vinyl (H)	2.00			LI	W	MF	Y		
GLVNLV	V-185	Glazing Vinyl (V)	2.00			LI	H	MF	Y		
HEADER	7002	Frame Top Extrusion	1.00		-.2500	LI	W	MF	Y		7002
JAMEXS	WOOD	Jamb Extension	2.00	.0000		LI	H	MF			WOOD
JAMEXT	WOOD	Jamb Extension	2.00		1.2500	LI	W	MF			WOOD
LJAMB	7002	Left Side Extrusion	1.00	-.2500		LI	H	MF	Y		7002
MULL	V-226	Mullion	1.00			LI	W	MF	Y		
NLFIN	1023	Nailing Fin	2.00			LI	H	MF	Y		
NLFIN	1023	Nailing Fin	2.00			LI	W	MF	Y		
RJAMB	7002	Right Side Extrusion	1.00	-.2500		LI	H	MF	Y		7002
SILL	7002	Bottom Extrusion	1.00		-.2500	LI	W	MF	Y		7002

End of Subassembly MF *****											

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/19/07
 NCTL-110-10908-01



Series 7010 TR

1 Piece Vinyl Fixed Transoms

- Maintenance Free Exterior
- Fully Welded Main Frame
- Mull "Prep": \$18.71 (Prepared for job-site mulling)
- 4-9/16 Jamb Extension: Add \$38.50
- 6-9/16 Jamb Extension: Add \$52.00

- 2 and 3 Piece Factory Mullled Units



Example: 3/0 Twin x 12" 2-Piece Transom
 Price: \$125.91 + \$125.91 + \$58.50 + \$18.71
 [(3/0 x 12") + (3/0 x 12") + Horizontal Mull
 + Vertical Mull]

Size	I/I	GGC	Low-E	Tempered
1-6 x 12"	94.49	104.51	4.38	21.06
2-0 x 12"	94.49	104.51	5.84	28.08
2-4 x 12"	105.00	116.13	6.81	32.76
2-6 x 12"	110.24	121.93	7.30	35.10
2-8 x 12"	115.49	127.73	7.79	37.44
3-0 x 12"	125.91	139.26	8.76	42.12
3-8 x 12"	139.57	154.36	10.71	51.48
4-0 x 12"	142.57	157.68	11.68	56.16
5-0 x 12"	151.59	167.66	14.60	70.20
6-0 x 12"	160.62	177.65	17.52	84.24
1-6 x 14"	108.66	120.18	5.11	24.57
2-0 x 14"	108.66	120.18	6.81	32.76
2-4 x 14"	120.75	133.55	7.95	38.22
2-6 x 14"	126.78	140.22	8.52	40.95
2-8 x 14"	132.81	146.89	9.08	43.68
3-0 x 14"	144.80	160.15	10.22	49.14
3-8 x 14"	160.51	177.52	12.49	60.06
4-0 x 14"	163.96	181.34	13.63	65.52
5-0 x 14"	174.33	192.81	17.03	81.90
6-0 x 14"	184.71	204.29	20.44	98.28
Custom Size	Next Larger Size + 59.00		2.92/sqft	14.04/sqft


* Windows with an 96 inch length are required to be tempered

** Please specify 2-piece, 3-piece or continuous when ordering

MGM Industries
 287 Freehill Road
 Hendersonville, TN 37075
 Office 1-800-476-5584
 Fax 1-615-822-6581

2/2/07 7010-7

TEST SPECIMEN COMPLIES



**Series 7010 TR
1 Piece Vinyl Fixed Transoms**

- Lineal "H" Mull: \$.21/inch
- Mull "Prep": \$18.71 (Prepared for job-site mulling)
- 4 9/16 Jamb Extensions: Add \$38.50
- 6 9/16 Jamb Extensions: \$52.00

- 2 and 3 Piece Factory Mulling Units



Example: 3/0 Twin x 12" 2-Piece Transom
Price: \$125.91 + \$125.91 + \$58.50 + \$18.71
[(3/0 x 12") + (3/0 x 12") + Horizontal Mull + Vertical Mull]

**** Please specify 2-piece, 3-piece or continuous when ordering**

Size	1/1	GC	Low-E	Tempered
2-0 x 18"	130.41	144.23	8.76	42.12
2-4 x 18"	144.89	160.25	10.22	49.14
2-6 x 18"	152.13	168.26	10.95	52.65
2-8 x 18"	159.38	176.27	11.68	56.16
3-0 x 18"	173.76	192.18	13.14	63.18
3-8 x 18"	192.60	213.02	16.06	77.22
4-0 x 18"	196.75	217.61	17.52	84.24
5-0 x 18"	209.20	231.38	21.90	105.30
6-0 x 18"	221.65	245.14	26.28	126.36
2-0x 24"	156.49	173.08	11.68	56.16
2-4 x 24"	173.88	192.31	13.63	65.52
2-6 x 24"	182.56	201.91	14.60	70.20
2-8 x 24"	191.26	211.53	15.57	74.88
3-0 x 24"	208.51	230.61	17.52	84.24
3-8 x 24"	231.12	255.62	21.41	102.96
4-0 x 24"	236.09	261.12	23.36	112.32
5-0 x 24"	251.03	277.64	29.20	140.40
6-0 x 24"	265.98	294.17	35.04	168.48
Custom Size	Next Larger Size + 59.00		2.92/sqft	14.04/sqft


* Windows with an 96 inch length are required to be tempered

MGM Industries

287 Freehill Road
Hendersonville, TN 37075
Office 1-800-476-5584
Fax 1-615-822-6581

2/2/07 7010-7A

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/19/07
 NCTL-110-10908-01



- ① M-7002 FRAME HEAD
- ② M-7002 FRAME SILL
- ③ M-7002 FRAME JAMB
- ④ M-185 GLAZING BEAD


MGM
 INDUSTRIES

287 FREEHILL ROAD
 HENDERSONVILLE, TN 37075
 1-800-476-5894
 PH-615-824-8572
 FX-615-822-4591

TITLE: Vertical and Horizontal Cut Logic
 MATERIALS:

PO#: 7010PW
 DATE: 01-10-07
 BY: R.GRAVES
 DWG#: Do Not Scale Drawing



APPLICATION TEST SPECIMEN COMPLIES WITH THESE DETAILS		REVISIONS		
NEXT ASSY.	REV.	DESCRIPTION	DATE	APPROVED
ANY DEVIATION IS NOTED. TEST COMPLETE: 9/19/07 NCTL-110-10908-01				



MGM INDUSTRIES 77 FREEHILL ROAD HENDERSONVILLE, TN 37075	DESCRIPTION: 7010 7006 Bendable Pictrue Window	ALL RADI TO BE 0.015 ALL WALL THK TO BE 0.100 UNLESS OTHERWISE SPECIFIED INTERNAL WALLS 0.050	DWG. NO. M-7002	REV.
	DATE 12/05/03	WEIGHT 0.984	AREA 1.577	BY: ABG
DO NOT SCALE DRAWING				

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/19/07
 NCTL-110-10908-01

Full Size




NOTE:	WT/FT:	AREA:
RIGID	.061	.098
FLEX	.004	.007

ALL RADI TO BE 0.015. ALL WALL THKS TO BE 0.062 UNLESS OTHERWISE SPECIFIED.

MGM INDUSTRIES 287 FREEHILL ROAD HENDERSONVILLE, TN 37075	DESCRIPTION:	SERIES#:	DWG. NO.:	REV.:
	Glazing Bead 5000		V-185	
	5600-6000-7006			
	7010-8006-8010	WT/FT:	AREA:	BY: RGraves
	DO NOT SCALE DRAWING	.066	.106	DATE: 10-06-01

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/19/07
 NCTL-110-10908-01






Decorative

Divider Dimensions -Fill dimensions where applicable - Please fill out a divider sheet for each divider size used.

Dimensions			Material		
<input type="checkbox"/> W_1 <u>.1215</u> "	<input type="checkbox"/> W_2 <u>.151</u> "	<input type="checkbox"/> W_3 <u>.1064</u> "	<input checked="" type="checkbox"/> Aluminum	<input type="checkbox"/> Steel - Galvanized	<input type="checkbox"/> Other _____
<input type="checkbox"/> H_1 <u>.1360</u> "	<input type="checkbox"/> H_2 <u>.715</u> "	<input type="checkbox"/> T_1 <u>.120</u> "	<input type="checkbox"/> Steel - Mild	<input type="checkbox"/> Steel - Stainless	

TEST SPECIMEN COMPLIES WITH THESE DETAILS. ANY DEVIATION IS NOTED. TEST COMPLETE: 9/19/07 NCTL-110-10908-01



Spacer Dimensions -Fill dimensions where applicable - Please fill out a spacer sheet for each spacer used whether spacer type or size.

Gap	Primary Seal	Secondary Seal	Material	Fill
<input type="checkbox"/> W ₁ <u>.576</u> "	<input checked="" type="checkbox"/> Butyl	<input checked="" type="checkbox"/> Butyl	<input type="checkbox"/> Aluminum	<input checked="" type="checkbox"/> Dessiccant
<input type="checkbox"/> W ₂ <u>.526</u> "	<input type="checkbox"/> PIB	<input type="checkbox"/> PIB	<input type="checkbox"/> Steel - Mild	<input type="checkbox"/> Air
<input type="checkbox"/> W ₃ <u>.076</u> "	<input type="checkbox"/> Polysulphide	<input type="checkbox"/> Polysulphide	<input type="checkbox"/> Steel - Stainless	<input type="checkbox"/> Other _____
<input type="checkbox"/> W ₄ _____ "	<input type="checkbox"/> Silicone	<input type="checkbox"/> Silicone	<input checked="" type="checkbox"/> Steel - Galvanized	
<input type="checkbox"/> H ₁ <u>.300</u> "	<input type="checkbox"/> Urethane	<input type="checkbox"/> Urethane	<input type="checkbox"/> Vinyl	
<input type="checkbox"/> H ₂ <u>.045</u> "	<input type="checkbox"/> None	<input type="checkbox"/> None	<input type="checkbox"/> Foam _____	
<input type="checkbox"/> H ₃ <u>.08</u> "	<input type="checkbox"/> Other _____	<input type="checkbox"/> Other _____	<input type="checkbox"/> Other _____	
<input type="checkbox"/> H ₄ <u>.084</u> "				
<input type="checkbox"/> H ₅ _____ "				
<input type="checkbox"/> T ₁ <u>.013</u> "				