




MGM Industries

*SIMULATION PERFORMANCE &
SOLAR HEAT GAIN REPORT*

*Series "8010"
Picture Window*

NCTL-110-10911-01



NATIONAL CERTIFIED TESTING LABORATORIES

FIVE LEIGH DRIVE • YORK, PENNSYLVANIA 17406 • TELEPHONE (717) 846-1200
FAX (717) 767-4100
www.nctlinc.com

Simulation Performance, Solar Heat Gain Coefficient, Visible Transmittance and Condensation Resistance Calculation Report

REPORT NO: NCTL-110-10911-01
SIMULATION DATE: 09/20/07
REPORT DATE: 09/20/07

Client: MGM Industries
287 Freehill Road
Hendersonville, TN 37075

Product Line: MGM Industries' Series "8010" Picture Window

Specification: NFRC 100-2004: "Procedure for Determining Fenestration Product U-Factors".
NFRC 200-2004: "Procedure for Determining Fenestration Product Solar Heat
Gain Coefficients and Visible Transmittance at Normal Incidence".
NFRC 500-2004: "Procedure for Determining Fenestration Product
Condensation Resistance Values".
Therm 5.x / Window 5.x NFRC Simulation Manual (Approved at test date)

**Procedures
and
Compliance:** All U-factor, Solar Heat Gain Coefficients, Visible Transmittance and
Condensation Resistance values were calculated using the following
characteristics: a default value of 0.30 solar absorptance for all products
other than window glazed wall and sloped glazing which have a solar
absorptance of 0.50. The best glazing option was used as the configuration
for SHGC and VT specialty products table. NCTL is a NFRC accredited
simulation laboratory and this simulation was conducted in full compliance
with NFRC requirements. This report does not constitute an opinion or
endorsement by the laboratory. Ratings values included in this report are for
submittal to an NFRC-licensed IA and are not meant to be used directly for
labeling purposes. Only those values identified on a valid Certification
Authorization Report (CAR) by an NFRC accredited Inspection Agency (IA) are
to be used for labeling purposes. Rounding per IEEE/ASTM SI 10-1997
except section 5.4.1.3.

PRODUCT LINE DESCRIPTION

General: The product line modeled is MGM Industries' Series "8010" Picture Window.

Model Size Simulations: 1200mm x 1500mm (47.244" x 59.055")

Note: All product drawings are included in Attachment A.

Weatherseals:

Location	Weather Seal Description
Head	(1) single strip of weather-strip
Jamb	(3) single strip of weather-strip

Reinforcement: None

Finish: Vinyl

Dividers: Where applicable, dividers were not modeled because the gap between dividers and lites were greater than 3mm. For Solar Heat Gain and Visual Light Transmittance default dividers less than 1" and greater or equal to 1" and default patterns were used for simulations.

Group Leaders: The following group leaders are actual simulated individual products per NFRC 4.2.4 and the NFRC Technical Interpretations where applicable. All remaining individual products' U-factors in the corresponding groups are represented by the group leader's U-factor.

COG Group Leader: Individual products which differ from another (base) individual product in glazing tint and/or obscurity (including obscure glass, fritted glass, and wired glass) only may be assumed to have the same U-factor as the base product unless this change is associated with a change in coating properties.

COG Group Leader:

Glazing ID	Glazing Description	U _{COG}
001	2mm AFG Clear / .553" Air / 2mm AFG Clear	0.481 *
002	2mm AFG TiAC#36 / .553" Air / 2mm AFG Clear	0.298 *

* Group Leader

Modeling Assumptions and Comments Deemed Important:**Sealing Rules:**

All cavities that are opened to the exterior within a frame section shall be modeled according to ISO 15099, Section 6.7.1, which states that cavities greater than 2mm but equal to or less than 10 mm shall be modeled as "slightly ventilated air cavities". For physical testing purposes the product is sealed at the inside surface with tape or equivalent to prevent air infiltration. Air cavities created by this sealing technique must be simulated with the standard NFRC "Frame Cavity" material. If cavities on the frame are sealed (covered) to the surround panel with tape or equivalent, those cavities are also filled with NFRC "Frame Cavity" material within the simulation model. If the frame is not covered or sealed, those areas are left hollow or opened within the simulation model.

Continuous elements:

All elements continuous within the product line are identified from the Bill-of-Materials and detailed drawings via the referenced dimensions and cut lengths as compared to the overall size of the product.

General Notes:

The Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation, and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.

Miscellaneous assumptions:

1. The screen extrusions were not modeled.
2. All radii are simulated at angles.
3. Any spacer simulated using a spacer system from the Frame Spacer Library match the required configurations for this manufacturer's spacer system.
4. The modeling was performed in accordance with the manufacturer's assembly drawing from a DXF file.

Component Area and Frame Heights:

Frame heights, calculated areas, area weighted values for U-factor, SHGC, and VT, and center -of-glazing are located in approved NFRC simulation programs for all individual products.

Specialty Products Table: The specialty products method allows the manufacturer to determine the overall product SHGC and VT for any glazing option. The center of glass SHGC and/or VT must be determined using WINDOW 5.2. The method gives overall product SHGC and VT indexed on center of glass properties.

SHGC	No Dividers	Dividers <1"	Dividers ≥1"
0.00	0.002	0.005	0.007
1.00	0.786	0.704	0.627

VT	No Dividers	Dividers <1"	Dividers ≥1"
0.00	0.000	0.000	0.000
1.00	0.784	0.699	0.619

$$SHGC = SHGC_0 + SHGC_{COG} (SHGC_1 - SHGC_0)$$

$$VT = VT_0 + VT_{COG} (VT_1 - VT_0)$$

NCTL Therm Section Filename Methodology

Filename Codes Example: CU_HD2_003.THM	
CU	Spacer (Intercept)
HD	Frame Section (Head)
2	Glass Size (2.5mm)
003	Glazing ID #3

Individual Product Descriptions and Model Size Matrix of U-Factors, SHGC, VT & CR

All U-factors are given in BTU/HR/ft²/°F

Product Description	Product Number	Pane ID (Exterior)	Pane ID (Interior)	Pane Thickness (Exterior)	Pane Thickness (Interior)	Gap	Gap Fill	% of Gap Fill	Emissivity Surface 2	Emissivity Surface 3	U-factor C-O-G	SHGC C-O-G	VT C-O-G	Spacer	Grid Type	Tint	U-factor	Condensation Resistance	Solar Heat Gain Coefficient (ND)	Visual Transmittance (ND)	Solar Heat Gain Coefficient (<1")	Visual Transmittance (<1")
CLR_SS_AIR	001	885	885	0.098	0.098	0.553	AIR				0.50	0.80	0.83	CU-D	N,G	CL	0.45	44	0.63	0.65	0.57	0.58
CLR_DS_AIR		887	887	0.118	0.118	0.514	AIR				0.50	0.79	0.82	CU-D	N,G	CL	0.45	44	0.62	0.64	0.55	0.57
TiAC36#2_SS_AIR	002	964	885	0.098	0.098	0.553	AIR		0.034		0.30	0.37	0.69	CU-D	N,G	LE	0.32	55	0.29	0.54	0.26	0.48
TiAC36#3_SS_AIR		885	964	0.098	0.098	0.553	AIR			0.034	0.30	0.47	0.69	CU-D	N,G	LE	0.32	55	0.37	0.54	0.33	0.48
TiAC36#3_DS_AIR	003	887	965	0.118	0.118	0.514	AIR			0.034	0.29	0.46	0.68	CU-D	N,G	LE	0.31	55	0.36	0.53	0.33	0.47
TiAC36#2_DS_AIR		965	887	0.118	0.118	0.514	AIR		0.034		0.29	0.37	0.68	CU-D	N,G	LE	0.31	55	0.29	0.53	0.26	0.47

A baseline product test in accordance with the "NFRC 102: Test Procedure for Measuring the Steady-State Thermal Transmittance of Fenestration Systems" is required in order to validate the "Model Size Matrix of U-Values" as previously indicated. Per Section 1.4.3 of NFRC 100-2004, "the baseline product is the individual product selected for validation testing". **The individual product selected as the baseline product shall be the lowest simulated individual product or an individual product having a simulated U-factor within 0.60 W/(m²*K) (0.10 BTU/HR/ft²/°F) or 20% of the listed lowest simulated U-factor.**

Note:

1. For lowest U-factor listings where multiple individual products are shown, validation testing can be conducted on any of the configurations listed.
2. Actual simulated individual products are required for product line validation testing.
3. All individual products in the product line were simulated using the approved NFRC THERM program.

-----> Res sizes

For the purposes of validation testing, production line units and sizes shall be used to represent the baseline product. Per the client, the model size is manufactured as part of their product line; therefore the previously listed model size can be used for baseline product validation testing.

Copies of this report and the detailed product drawings will be retained by NCTL for a period of four (4) years. This report may not be reproduced, except in full, without the approval of NCTL. The results only to the fenestration product simulated. The attached diskette(s) contain(s) all required NFRC data and software files.

NATIONAL CERTIFIED TESTING LABORATORIES



JUSTIN M. ROBINSON

NFRC Accredited Simulator

Simulator-In-Responsible-Charge

Attachments

Report Log

Product Line: *MGM Industries' Series "8010" Picture Window*

Date:
09/20/07 - *Original Report issued to MGM Industries and Inspection Agency*

NFRC CODES

Door	
Code	Description
EM	Embossed
FL	Flush
LF	Full Lite
LH	1/2 - Lite
LQ	1/4 - Lite
LT	3/4 - Lite
N	Not Applicable
RP	Raised Panel

Grid	
Code	Description
G	Grids between the glass
N	No Muntins
S	Simulated Divided Lites
T	True Muntins

Sealant	
Code	Description
D	Dual Seal Spacer System
N	Not Applicable
S	Single Seal Spacer System

Gap Fill	
Code	Description
AIR	Air
AR3	Argon/Krypton/Air Mixture
ARG	Argon
KRY	Krypton
N	Not Applicable

Glass Tint	
Code	Description
AZ	Azurlite
BG	Blinds between the Glazing
BL	Blue
BZ	Bronze
CL	Clear
DV	Dynamic Glazing (Variable)
DY	Dynamic Glazing (Non-Variable)
EV	Evergreen
GC	Gold (reflective coating)
GD	Gold
GR	Green
GY	Gray
LE	Low 'e' Coating
OT	Other (use comment field)
RC	Solar or Reflective Coating
RG	Roller shades between Glazing
RS	Silver (reflective coating)
SF	Suspended Polyester Film
SR	Silver

Spacer		
Code	Type	Definition
A1-D	Aluminum	Aluminum spacer system - dual sealed.
A1-S	Aluminum	Aluminum spacer system - single sealed.
A2-D	Aluminum (thermally-broken)	Thermally improved aluminum spacer system - dual sealed.
A2-S	Aluminum (thermally-broken)	Thermally improved aluminum spacer system - single sealed.
A3-D	Aluminum-reinforced polymer	Polymer spacer material with aluminum substance - dual sealed.
A3-S	Aluminum-reinforced polymer	Polymer spacer material with aluminum substance - single sealed.
A4-D	Aluminum/Wood	Composite spacer system of two materials - dual sealed.
A4-S	Aluminum/Wood	Composite spacer system of two materials - single sealed.
A5-D	Aluminum-reinforced butyl	Butyl spacer material with aluminum substrate - dual sealed.
A5-S	Aluminum-reinforced butyl	Butyl spacer material with aluminum substrate - single sealed.
A6-D	Aluminum/Foam/Aluminum	Two aluminum spacers separated by foam-type material - dual sealed
A6-S	Aluminum/Foam/Aluminum	Two aluminum spacers separated by foam-type material - single sealed
A7-D	Aluminum U-shaped	U-shaped spacer system embedded in sealant - dual sealed.
A7-S	Aluminum U-shaped	U-shaped spacer system embedded in sealant - single sealed.

Spacer		
Code	Type	Definition
A8-D	Aluminum-Butyl Composite	Exposed corrugated aluminum spacer with butyl - dual sealed.
A8-S	Aluminum-Butyl Composite	Exposed corrugated aluminum spacer with butyl - single sealed.
CS-D	Coated Steel	Coated Steel (galvanized or tinplated) - Dual seal
CS-S	Coated Steel	Coated Steel (galvanized or tinplated) - Single seal
CU-D	Coated Steel U-Shaped	Coated Steel (galvanized or tinplated) U-shaped spacer system embedded in sealant - Dual sealed
CU-S	Coated Steel U-Shaped	Coated Steel (galvanized or tinplated) U-shaped spacer system embedded in sealant - Single sealed
ER-D	EPDM Reinforced Butyl	EPDM reinforced butyl spacer system - dual sealed.
ER-S	EPDM Reinforced Butyl	EPDM reinforced butyl spacer system - single sealed.
FG-D	Fiberglass	Fiberglass - dual sealed.
FG-S	Fiberglass	Fiberglass - single sealed.
GL-S	Glass	Welded glass edge condition at glazing perimeter.
N	Not Applicable	
OF-D	Organic Foam	Organic-based foam spacer system - dual sealed.
OF-S	Organic Foam	Organic-based foam spacer system - single sealed.
P1-D	Polycarbonate- Butyl Composite	Exposed corrugated polycarbonate spacer with butyl - dual sealed.
P1-S	Polycarbonate- Butyl Composite	Exposed corrugated polycarbonate spacer with butyl - single sealed.
PU-D	Polyurethane foam	Polyurethane foam - dual sealed.
PU-S	Polyurethane foam	Polyurethane foam - single sealed.
S2-D	Steel (thermally-broken)	Stainless steel spacer with urethane thermal break - dual sealed.
S2-S	Steel (thermally-broken)	Stainless steel spacer with urethane thermal break - single sealed.
S3-D	Steel/Foam/Steel	Two steel spacers separated by foam-type material - dual sealed.
S3-S	Steel/Foam/Steel	Two steel spacers separated by foam-type material - single sealed.
S5-D	Steel reinforced butyl	Butyl spacer material with stainless steel substrate - dual sealed.
S5-S	Steel reinforced butyl	Butyl spacer material with stainless steel substrate - single sealed.
S6-D	Steel U-channel w/ thermal cap	U-shaped steel spacer system with a thermal cap - dual sealed.
S6-S	Steel U-channel w/ thermal cap	U-shaped steel spacer system with a thermal cap - single sealed.
SS-D	Stainless Steel	Stainless Steel - Dual Seal
SS-S	Stainless Steel	Stainless Steel - Single Sealed
SU-D	Stainless Steel U-Shaped	Stainless Steel U-shaped spacer system embedded in sealant - Dual sealed
SU-S	Stainless Steel U-Shaped	Stainless Steel U-shaped spacer system embedded in sealant - Single sealed
TP-D	Thermo-plastic	Thermo-plastic - dual sealed.
TP-S	Thermo-plastic	Thermo-plastic - single sealed.
TS-D	Thermo-plastic	Thermoplastic spacer with stainless steel substrate - dual-sealed
TS-S	Thermo-plastic	Thermoplastic spacer with stainless steel substrate - single-sealed
WD	Wood	Wood spacer system
ZF-D	Silicone Foam	Silicone foam spacer system - dual sealed.
ZF-S	Silicone Foam	Silicone foam spacer system - single sealed.
ZS-D	Silicone/Steel	Combination of two separate spacers: a steel spacer and silicone spacer - dual sealed.
ZS-S	Silicone/Steel	Combination of two separate spacers: a steel spacer and silicone spacer - single sealed.

ATTACHMENT A

Product Drawings

TEST SPECIMEN COMPLIES WITH THESE DETAILS.

ANY DEVIATION IS NOTED.

TEST COMPLETE: 9/20/07

NCTL-110-10911

Bill of Materials Listing

Print Date: 09/21/07

Product: 8010

Type: PIC

Assembly Code	Part #	Description	Qty	<---Deducts--->		Unit Code	Vert Hor	Sub Assy	Add Color	Fixed Length	W/Nailing Fin
				Height	Width						
ASSCR1	8X1PH	Assembly Screw #1	4.00			EA		IA	Y		8X1PH
GLASS	1CL	Default Glass Type	1.00	6.1250	4.0000	SF		IA	N		1CL
GLSSPC	SWG-9/16	Glass Spacer	2.00		4.8025	LI	W	IA	N		SWG-9/16
GLSSPC	SWG-9/16	Glass Spacer	2.00	4.6250		LI	H	IA	N		SWG-9/16
HEADER	8022	Frame Top Extrusion	1.00		3.8750	LI	W	IA	Y		8022
LJAMB	8000	Left Side Extrusion	1.00	2.6875		LI	H	IA	Y		8000
MISC	1X3/4X1/16	Glass Setting Blocks	4.00			EA		IA	N		1X3/4X1/16
MUNCLP	10946-002	Muntin Clips	1.00			EA		IA	N		10946-002
MUNTINH	536006	Muntin Bar Horizontal	1.00		3.8025	LI	W	IA	Y		536006
MUNTINV	536006	Muntin Bar Vertical	1.00	3.9375		LI	H	IA	Y		536006
RJAMB	8000	Right Side Extrusion	1.00	2.6875		LI	H	IA	Y		8000
SILL	8002	Bottom Extrusion	1.00		3.8750	LI	W	IA	Y		8002
VSWEEP	391	Vinyl Sweep	1.00		3.1250	LI	W	IA	Y		391
WTSTPH	W432519W	Weather Strip(H)	2.00		3.0000	LI	W	IA	N		
WTSTPV	W432519W	Weather Strip(V)	4.00	2.9375		LI	H	IA	N		

End of Subassembly IA *****											
ASSCR1	10X1TRUSS	Assembly Screw #1	4.00			EA		MF	N		10X1TRUSS
BRCKLJ	V-367	Brickmold Left Jamb	1.00	-.6875		LI	H	MF	Y		
BRCKMH	V-367	Brickmold Head	1.00		-1.7500	LI	W	MF	Y		
BRCKRJ	V-367	Brickmold Right Jamb	1.00	-.6875		LI	H	MF	Y		V-367
HDADPT	VR-2180	Header Adapter	3.00		.0000	LI	W	MF	Y		VR-2180
HEADER	V-397	Frame Top Extrusion	1.00		-.2500	LI	W	MF	Y		V-397
JAMEXS	WOOD	Jamb Extension	2.00	.0000		LI	H	MF			WOOD
JAMEXT	WOOD	Jamb Extension	2.00		1.2500	LI	W	MF			WOOD
LJAMB	V-397	Left Side Extrusion	1.00	-.0625		LI	H	MF	Y		V-397
MISC	ERSCW006D4534	Jamb-To-Sill-Pad	2.00			EA		MF	Y		ERSCW006D453

TEST SPECIMEN COMPLIES WITH THESE DETAILS.

ANY DEVIATION IS NOTED.

Bill of Materials Listing

Print Date: AUG 17 2007

TEST COMPLETE: 9/20/07
NCTL-110-10911

Product: 8010

Type: PIC

<---Deducts--->

Assembly Code	Part #	Description	Qty	Height	Width	Unit Code	Vert Hor	Sub Assy	Add Color	Fixed Length	W/Nailing Fin
MISC	SRLABEL	Miscellaneous	1.00			EA		MF			SRLABEL
MISCLI	WRAP	Micellaneous	20.00			LI	W	MF			WRAP
NLFIN	42026	Nailing Fin	1.00			LI	W	MF	N		
RJAMB	V-397	Right Side Extrusion	1.00	.0625		LI	H	MF	Y		V-397
SCAULK	896CTG789	Silicone Caulk	.20			EA		MF			896CTG789
SILANG	8096	Sill Adapter	1.00		1.8750	LI	W	MF	Y		8096
SILL	V-294	Bottom Extrusion	1.00		.5625	LI	W	MF	Y		V-294
SILN	V-295	Sill-Nose	1.00		1.6250	LI	W	MF	Y		V-295


End of Subassembly MF		*****									
CKEYS	V6-611	Corner Keys	2.00			EA		SC	N		
CKEYS	V6-211	Corner Keys	2.00			EA		SC	N		

HEADER	V11BLWT3B	Frame Top Extrusion	1.00		3.8125	LI	W	SC	N		
LJAMB	V11BLWT3B	Left Side Extrusion	1.00	4.5625		LI	H	SC	N		
LSPRNG	V8-3769	Leaf Spring	2.00			EA		SC	N		

MISC	GA-817	Center-Bar-Insert	1.00		.0000	EA		SC	N		
RJAMB	V11BLWT3B	Right Side Extrusion	2.00	4.5625		LI	H	SC	N		
SCDEDF	1	Full Screen Deduct		4.5625	3.8125			SC			1
SCDEDH	1	Half Screen Deduct		.1250	4.5625			SC			1
SCLOTH	1816	Screen Cloth(Std)	1.00	.2500	4.6250	SF		SC	N		1816
SCLOTW	1816	Screen Cloth(Wire)	1.00			SF		SC	N		1816W
SILL	V11BLWT3B	Bottom Extrusion	1.00		3.8125	LI	W	SC	N		
SSPLIN	.140	Screen Spline	2.00	.2500		LI	H	SC	N		
SSPLIN	.140	Screen Spline	2.00	.0000	4.2500	LI	W	SC	N		.140

End of Subassembly SC		*****									

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/20/07
 NCTL-110-10911



Series 8010 PIC

Vinyl Fixed Picture Windows

- 6-9/16" Jamb Extension: Add \$36.25
- Custom sizes available


Fixed Windows

Size	I/I	GBC	Lite	Low-E	Tempered
2-0 x 3-0	172.23	188.59	8	17.52	84.24
2-0 x 3-8	180.09	197.20	8	21.41	102.96
2-0 x 4-0	184.02	201.50	8	23.36	112.32
2-0 x 4-4	187.98	205.84	8	25.31	121.68
2-0 x 5-0	195.84	214.44	8	29.20	140.40
2-0 x 5-4	195.84	214.44	8	31.15	149.76
2-0 x 6-0	210.67	230.68	12	35.04	168.48
2-8 x 3-0	188.76	206.69	12	23.36	112.32
2-8 x 3-8	225.77	247.22	12	28.55	137.28
2-8 x 4-0	269.00	294.56	12	31.15	149.76
2-8 x 4-4	269.00	294.56	12	33.74	162.24
2-8 x 5-0	341.62	374.07	12	38.93	187.20
2-8 x 5-4	341.62	374.07	12	41.53	199.68
2-8 x 6-0	403.08	441.37	18	46.72	224.64
3-0 x 3-0	197.48	216.24	12	26.28	126.36
3-0 x 3-8	234.50	256.78	12	32.12	154.44
3-0 x 4-0	277.71	304.09	12	35.04	168.48
3-0 x 4-4	277.71	304.09	12	37.96	182.52
3-0 x 5-0	352.11	385.56	12	43.80	210.60
3-0 x 5-4	352.11	385.56	12	46.72	224.64
3-0 x 6-0	411.80	450.92	18	52.56	252.72
4-0 x 3-0	225.87	247.33	16	35.04	168.48
4-0 x 3-8	287.23	314.52	16	42.83	205.92
4-0 x 4-0	376.99	412.80	16	46.72	224.64
4-0 x 4-4	376.99	412.80	16	50.61	243.36
4-0 x 5-0	441.53	483.48	16	58.40	280.80
4-0 x 5-4	441.53	483.48	16	62.29	299.52
4-0 x 6-0	518.11	567.33	24	70.08	336.96
5-0 x 3-0	366.17	400.96	20	43.80	210.60
5-0 x 3-8	384.97	421.54	20	53.53	257.40
5-0 x 4-0	455.84	499.14	20	58.40	280.80
5-0 x 4-4	455.84	499.14	20	63.27	304.20
5-0 x 5-0	514.49	563.37	20	73.00	351.00
5-0 x 5-4	514.49	563.37	20	77.87	374.40
5-0 x 6-0	615.72	674.21	30	87.60	421.20
6-0 x 3-0	493.10	539.94	24	52.56	252.72
6-0 x 3-8	501.85	549.53	24	64.24	308.88
6-0 x 4-0	515.04	563.97	24	70.08	336.96
6-0 x 4-4	597.85	654.65	24	75.92	365.04
6-0 x 5-0	677.80	742.19	24	87.60	421.20
6-0 x 5-4	677.80	742.19	24	93.44	449.28
*6-0 x 6-0	752.23	823.69	36	105.12	505.44
Custom Size	Next Larger Size + 67.50			2.92/sqft	14.04/sqft


* Windows with over 30 sqft of glass are required to be tempered

MGM Industries
 287 Freehill Road
 Hendersonville, TN 37075
 Office 1-800-476-5584
 Fax 1-615-822-6581

TEST SPECIMEN COMPLIES WITH THESE DETAILS. ANY DEVIATION IS NOTED. TEST COMPLETE 9/20/07
NCTL-101011



TITLE: Vertical and Horizontal Cross-Section	DATE: 05/02/05
SERIES: 8010 Picture Window	DRAWN BY: RGraves
287 Freshhill Road Hendersonville, TN 37075 Phone: (615) 822-8581 Fax: (615) 822-8581	
Do Not Scale	




TEST SPECIMEN COMPLIES WITH THESE DETAILS.

ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/20/07
 NCTL-110-10911

REVISIONS

REV.	DESCRIPTION	DATE	APPROVED



MGM INDUSTRIES
 287 FREEHILL ROAD
 HENDERSONVILLE, TN
 37075

615-824-6572
 DO NOT SCALE DRAWING

DESCRIPTION:
 Snap-in Header

DATE 09/20/04

ALL RADI TO BE 0.015
 ALL WALL THK TO BE 0.062


WEIGHT 0.109
 AREA 0.174

DWG. NO.
 M-401

REV.


BY: ABG

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS.
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/20/07
 NCTL-110-10911





MGM INDUSTRIES 287 FREEHILL RD HENDERSONVILLE, TN 37075	DESCRIPTION: Bottom Sash Bottom Rail	ALL RADI TO BE 0.015. ALL WALL THK TO BE 0.0625 UNLESS OTHERWISE SPECIFIED. ALL INTERNAL RADI .052	DWG. NO.: V-8002	REV.: 4
	DO NOT SCALE	DATE: 08/11/00	AREA .7808	WT/FT .4863
			BY: ABG	

APPLICATION		REVISIONS		
REV.	DESCRIPTION	DATE	APPROVED	
TEST SPECIMEN COMPLIES WITH THESE DETAILS. ANY DEVIATION IS NOTED. TEST COMPLETE: 9/20/07 NCTL-110-10911				



MGM INDUSTRIES 287 FREEHILL ROAD HENDERSONVILLE, TN 37075 615-824-6572 DO NOT SCALE DRAWING	DESCRIPTION: 8010/5600 picture window sill	ALL RADI TO BE 0.015 ALL WALL THK TO BE 0.065 UNLESS OTHERWISE SPECIFIED INTERNAL WALLS 0.050	DWG. NO. M-8096A	REV.
	DATE 04/07/05	WEIGHT 0.209	AREA 0.335	BY: ABG

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS.
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/20/07
 NCTL-110-10911




MGM INDUSTRIES 287 FREEHILL RD HENDERSONVILLE, TN 37075	DESCRIPTION: 8000 Series Sash		ALL RADI TO BE 0.015. ALL WALL THK TO BE 0.0625 UNLESS OTHERWISE SPECIFIED	DWG. NO. V-8000	REV. 1
	DO NOT SCALE				
	DATE: 02/07/00	AREA .4959	WT/FT .3094	DRAWN BY: R.Graves	

Revisions:


TEST SPECIMEN COMPLIES WITH THESE DETAILS. ANY DEVIATION IS NOTED. TEST COMPLETED BY: NCTL-110-10911

ACTUAL SIZE



Unmarked Radii: .015		All Corners: .015		Radius Unless Specified:		Title: 8006 Nail Fin		Alloy/Temper: 6063-T6 Aluminum		Vendor Die Number: 22095 A	
8006 Nail Fin		Unspecified Wall Thickness: .060		Est. Area: .245		Scale: 2 X 1		Series#: 8000		BY: R.Graves	
Vendor: Alcoa Extruded Construction Products		Est. Perimeter: 8.219		Est. Wt. Per Ft.: .294		Date: 05/15/02		Customer #: A-127			
MGM		INDUSTRIES, INC.		287 Freet-Hill Road		Hendersonville, Tennessee 37075		(615)-824-6572			

TEST SPECIMEN COMPLIES
 WITH THESE DETAILS.
 ANY DEVIATION IS NOTED.
 TEST COMPLETE: 9/20/07
 NCTL-110-10911






Decorative

Divider Dimensions - Fill dimensions where applicable - Please fill out a divider sheet for each divider size used.

Dimensions			Material		
<input type="checkbox"/> W_1 <u>.1215</u> "	<input type="checkbox"/> W_2 <u>.151</u> "	<input type="checkbox"/> W_3 <u>.1064</u> "	<input type="checkbox"/> Aluminum	<input type="checkbox"/> Steel - Galvanized	<input type="checkbox"/> Other _____
<input type="checkbox"/> H_1 <u>.1360</u> "	<input type="checkbox"/> H_2 <u>.1715</u> "	<input type="checkbox"/> T_1 <u>.120</u> "	<input type="checkbox"/> Steel - Mild	<input type="checkbox"/> Steel - Stainless	

TEST SPECIMEN COMPLIES WITH THESE DETAILS. ANY DEVIATION IS NOTED. TEST COMPLETE: 9/20/07 NCTL-110-10911



Spacer Dimensions -Fill dimensions where applicable - Please fill out a spacer sheet for each spacer used whether spacer type or size.

Gap	Primary Seal	Secondary Seal	Material	Fill
<input type="checkbox"/> W ₁ <u>1/2</u> "	<input checked="" type="checkbox"/> Butyl	<input checked="" type="checkbox"/> Butyl	<input type="checkbox"/> Aluminum	<input checked="" type="checkbox"/> Dessicant
<input type="checkbox"/> W ₂ <u>.45</u> "	<input type="checkbox"/> PIB	<input type="checkbox"/> PIB	<input type="checkbox"/> Steel - Mild	<input type="checkbox"/> Air
<input type="checkbox"/> W ₃ <u>.076</u> "	<input type="checkbox"/> Polysulphide	<input type="checkbox"/> Polysulphide	<input type="checkbox"/> Steel - Stainless	<input type="checkbox"/> Other _____
<input type="checkbox"/> W ₄ _____ "	<input type="checkbox"/> Silicone	<input type="checkbox"/> Silicone	<input checked="" type="checkbox"/> Steel - Galvanized	
<input type="checkbox"/> H ₁ <u>1300</u> "	<input type="checkbox"/> Urethane	<input type="checkbox"/> Urethane	<input type="checkbox"/> Vinyl	
<input type="checkbox"/> H ₂ <u>7045</u> "	<input type="checkbox"/> None	<input type="checkbox"/> None	<input type="checkbox"/> Foam _____	
<input type="checkbox"/> H ₃ <u>108</u> "	<input type="checkbox"/> Other _____	<input type="checkbox"/> Other _____	<input type="checkbox"/> Other _____	
<input type="checkbox"/> H ₄ <u>1084</u> "				
<input type="checkbox"/> H ₅ _____ "				
<input type="checkbox"/> T ₁ <u>1013</u> "				